

SYSTEM SHUTDOWN NOTICE

If your Surna equipment is being shut down for planned preventative maintenance, repair, or troubleshooting, you **MUST** follow this sequence:

- 1. SHUT OFF CHILLERS**
- 2. WAIT FIVE MINUTES**
- 3. SHUT OFF PUMP**
- 4. CLOSE RESERVOIR RETURN VALVES (OPEN SYSTEMS ONLY)**

If during shutdown, the chillers are run without the water circulating pumps, this could cause **SERIOUS AND IRREVERSIBLE DAMAGE** to the chillers, pumps, and piping. This will also **VOID YOUR WARRANTY**.